

CERTIFICATE OF COMPLIANCE

Certificate Number E516625
Report Reference E516625-20220302
Date 2022-March-03

Issued to: HAUBER-Elektronik GmbH
Fabrikstrasse 6
Nuertingen 72622 DE

**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 121201 and CSA C22.2 No. 213-17,
Nonincendive Electrical Equipment for Use in Class I and
II, Division 2 and Class III, Divisions 1 and 2 Hazardous
(Classified) Locations

Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




CERTIFICATE OF COMPLIANCE

Certificate Number E516625
Report Reference E516625-20220302
Date 2022-March-03

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Product(s):

Process Control Equipment Vibration sensors, Models HE200, HE205, HE250 or HE255, f/b 02, f/b any two or three numbers or characters (not safety relevant), f/b any two or three numbers or characters (not safety relevant), f/b 00, 01, 02, 50, 51 or 52, f/b 00, 01 or 02, f/b any number, for use in and providing nonincendive field wiring for Class I, Division 2, Groups A, B, C and D, Class II, Groups F and G and Class III Hazardous Locations when installed in accordance with Control Drawing no. M003-H20x / M003-H25x.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

